ENGINEERING SPECIFICATIONS

Standards

Underwriters Laboratories Standards UL-83, UL-1569, UL-1581, UL-2556 for type MC; Federal Specification A-A59544; NEMA RV 1-2014, NEMA WC70/ICEA S-95-658; IEEE 1202 (70,000 Btu/hr) Vertical Cable Tray Flame Test; NFPA 70 (NEC®) Article 330; ARRA 2009 Section 1605 "Buy American" Compliant; RoHS Compliant; MasterSpec Division 26 Sections 260519, 260523; UL Listing #E-301130







APPLICATIONS

Type MC cable shall be permitted as follows:

- · Permitted use for branch circuits in industrial, commercial, and multi-residential buildings;
- Acceptable for power, lighting, control, and signal circuits;
- Allowable in concealed or exposed systems;
- Permitted use in dry locations and embedded in plaster finish on brick or other masonry except in damp or wet locations;
- Utilized for environmental air-handling spaces (NEC 300.22(C)(1));
- Allowable in assembly occupancies (NEC 518.4);
- · Permissible in theaters, audience areas of motion pictures, television studios, and similar locations (NEC 520.5);
- Allowable installations in approved raceways and cable trays (NEC 392);
- Suitable for installation under raised floors for IT equipment (NEC 645.5(E));
- Permitted in Class I Div. 2, Class II Div. 2, and Class III Div. 1 Hazardous Locations;
- Listed for use with UL 1479 1, 2, and 3 Hour Through-Penetration Firestop Systems.

CONSTRUCTION

Available in sizes 12 AWG and 10 AWG with two (2) insulated ground conductors. Encore's Metal-Clad Cable is constructed with soft-drawn copper, Type THHN/THWN-2 conductors rated 90°C dry locations. The two grounding conductors are distinguished by color code: one (1) solid green, and one (1) solid green with yellow stripe. All conductors are cabled together with a separator tape containing the identification print legend to form the cable core. Interlocked aluminum armor is applied over the entire assembly.



- Removable SmartColorID¹ Label
- Interlocked Aluminum Armor
- Separator Tape
- 4 Isolated Ground featuring SmartStripe
- **5** Ground Conductor
- 6 THHN/THWN-2 Solid or Stranded Copper Conductor

Circuit Conductors		Ground Conductors	Overall Diameter	Approximate Net Weight	Allowable Ampacity (Amps) ²		Standard Packaging (ft)	
AWG/No.	Туре	(AWG/No.)	(in)	(lbs/1000 ft)	75°C	90°C	Coils	Reels
12/2	Solid	12/2	0.505	132	25	30	250'	1000'
12/3	Solid	12/2	0.539	158	25	30	250'	1000'
12/4	Solid	12/2	0.574	186	25	30	250'	1000'
10/2	Solid	10/2	0.580	193	35	40	250'	1000'
10/3	Solid	10/2	0.623	236	35	40	250'	1000'
10/4	Solid	10/2	0.668	276	35	40	250'	1000'
12/2	Stranded	12/2	0.527	137	25	30	250'	1000'
12/3	Stranded	12/2	0.564	165	25	30	250'	1000'
12/4	Stranded	12/2	0.602	194	25	30	250'	1000'
10/2	Stranded	10/2	0.607	201	35	40	250'	1000'
10/3	Stranded	10/2	0.653	243	35	40	250'	1000'
10/4	Stranded	10/2	0.701	288	35	40	250'	1000'

¹ SmartColorID manufactured under Patent No. 7,954,530, 8,454,785, 8,826,960 & 8,905,108

When the neutral is considered current-carrying conductor, the ampacity of 4/C cables shall be reduced by a factor of 0.80 per NEC 310.15(C)(1).

The above data is approximate and subject to normal manufacturing tolerances.

FEATURES

Installation costs reduced up to 50% over raceway and wire. Weight of aluminum armor is as much as 45% less than steel. SmartColorID labels are spaced at regular intervals on the exterior of the metal sheathing and are removable. For ease of installation and pulling, cable is reverse wound on reels. Coils are designed to be pulled from the inside.

MC Cable Connectors are required to be listed for use with MC Cable per 330.6. Anti-Short Bushings are not

Standard Conductor Color Coding

No.	277V/480V				
2	Black/White				
3	Black/Red/White				
4	Black/Red/Blue/White				
Ground	Green				
Isolated Ground	Green w/ Yellow SmartStripe				

SmartColorID Legend:



Ampacity of conductors are based on the National Electrical Code (NFPA 70) Table 310.16. See 110.14(C), 240.4(D) and 310.15(B)&(C) for other limitations where applicable.

For equipment marked for use at higher temperatures, the conductor ampacity shall be limited to the following per NEC 110.14(C): 60°C when terminated to equipment for circuits rated 100 amperes or less or marked for size 14 AWG through 1 AWG conductor.

^{75°}C when terminated to equipment for circuits rated over 100 amperes or marked for conductors larger than 1 AWG.

^{90°}C for ampacity derating purposes.